



APPROVED

Date

Signature

General tolerances ISO 2768-m

Pos	Qty	Name	Draw-No. / Material	Remarks
8	1	Sensor holder	21-14000-524-008 / -	-
7	1	Sensor tube	21-14000-524-007 / -	-
6	1	Perforated sheet	21-14000-524-004 / -	-
5	1	Side sheet right	21-14000-525-007 / -	-
4	1	Side sheet left	21-14000-524-006 / -	-
3	2	Heating elements 40x80	- / -	500W, 240V
2	1	Ex-e Cable gland M20x1.5	- / Polyamid	Cable- \varnothing 5,5...13mm
1	1	Connection box	- / Polyester	120x220x91

Replacement for:	-	Name:		Date:	23.05.2017	Scale:	1:2
Replaced by:	-	Drafted:	DF	Checked:	-		
Origin:	A3	Released:	ZG	Released:	23.05.2017		
 		Explosionproof roomheater HEXFA. 12S 2x500W, 240V					
thuba Ltd. CH-4015 Basel Phone: +41 61 307 80 00 Fax : +41 61 307 80 10		Designation:		21-14000-524		Index:	
		Drawing No.:		21-14000-524		Index:	
		EDP No.:		OF914630 Explosionproof roomheater HEXFA. 12S 2x500W, 240V		-	